



Essex County
Fire & Rescue Service

Extract Copy of Fire Report

Details At Call

| | |
|----------------------------|----------------------------|
| Incident Number: | ██████████ |
| Time of Call: | ██████████/2019 8:10:02 AM |
| Incident Type at Control: | Fire - Building |
| Late Call: | No |
| Station Groud of Incident: | Hawkwell |
| Time of Stop Message: | ██████████/2019 8:31:22 AM |
| Time Incident Closed: | ██████████/2019 9:54:59 AM |

Details At Attendance

| | |
|--|---|
| Incident Type: | Fire |
| Property Type: | Property/Building/Non Residential/Education/Infant/primary school |
| Persons Rescued, Extricated, or Killed: | No |
| Persons Evacuated: | No |
| Pumping Appliances Deployed Before Mobilising Stopped: | 2 |

Incident Location

| | |
|-------------------------|------------|
| Building Name / Number: | ██████████ |
| Street: | ██████████ |
| Town: | HAWKWELL |
| Post Code: | ██████████ |



Essex County
Fire & Rescue Service

Extract Copy of Fire Report

Additional Information

| | |
|-------------------------------------|--------------------------|
| Fire Multiple Seated: | No |
| Ignition to Discovery Time: | Immediately |
| Discovery to First Call Time: | Immediately |
| How was the Fire Discovered: | Person |
| Do Fire Regulations Apply: | Yes |
| Means of Escape: | OK - no visible concerns |
| Compartmentation: | Stopped/Checked spread |
| Alarm System Present: | Yes |
| Alarm System Type (1): | Smoke alarm - mains |
| Alarm System Location: | On same floor as fire |
| Alarm System Operated: | Yes and raised alarm |
| Anyone in Building at Time of Fire: | Yes |
| Is the Building Normally Occupied: | Yes - occupied |
| Cause/Motive: | Accidental |
| Hazmats Involved: | No |

Action

| | |
|--|-----------------|
| Delay in Commencing Fire Fightin Actions: | No delay |
| Main Action Taken by Publich Prior to Arrival: | None |
| Main Action Taken by FRS Personnel: | No firefighting |
| Manual Systems Used: | No |
| Building Fire Fighting Facilities Present: | No |
| Active Safety Systems Present: | No |



Essex County
Fire & Rescue Service

Extract Copy of Fire Report

| Damage | |
|--|---|
| Cause of the Fire: | Negligent use of equipment or appliance (heat source) |
| Source of Ignition: | Heating equipment - heating equipment |
| Ignition Powered by: | Electric |
| First Item Ignited: | electric heater |
| Item Mainly Responsible for Spread: | Foam, rubber, plastic - Rubber - raw material only |
| Rapid Fire Growth Cause: | No rapid fire growth |
| Dangerous Substances Involved: | None |
| Explosion Involved: | No |
| Location of Origin: | Office |
| Contributing Human Factors: | Small rubber toy had been put in heater |
| Was Impairment due to Suspected Drugs/Alcohol a Contributory Factor in the Fire: | No |
| Special Method of Building Construction: | None |
| Only Heat and Smoke Damage: | Yes |
| Fire Damaged Area at Stop: | None |
| Total Damaged Area at Stop: | None |

Signed:

A handwritten signature in black ink, appearing to read 'Ana M Tuckwell'.

Ana M Tuckwell |
Information Governance Manager & Deputy DPO Systems and Data Department

Date: 23/02/2023